



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-101, **Version:** 2

---

Appeal of Karen Hupp to an Egress Window Non-Compliance Determination at 873 JENKS AVENUE.

The windows are good operating replacement windows that were in the house when we purchased it.

June 29, 2011

Yes, 2 inches in openable height. No hearing necessary.

WHEREAS, in the matter of the appeal of Karen Hupp to an Egress Window Non-Compliance Determination at 873 JENKS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all three bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.