



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 11-264, **Version:** 2

Appeal of Joseph Uebel to a Fire Certificate of Occupancy Correction Notice at 1898-1900 FORD PARKWAY.

Window size 1 inch short.

July 20, 2011

Yes, 1 inch in height of egress opening.

WHEREAS, in the matter of the appeal of Joseph Uebel to a Fire Certificate of Occupancy Correction Notice at 1898-1900 FORD PARKWAY, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress bedroom windows in all four bedrooms measuring 23 inches high by 33 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.