STAMP - Activities

New Search

Help using this report

Run Date:

03/10/25 11:23 AM

Sort by Most Recent Date

Starting Date:

House#:

Folder Type: All Folder Types

✓ Ending Date:

Street Name:

Folder Count: 44

Include Same PIN Addresses: Yes

SERVING REA. RELOCATE ONE THERMOSTAT WHERE WALL IS BEING

REMOVED.

Click on address links below to access mapping services and Ramsey County info.

Click on ID# link below to view detail

DINI-022822210262

PIN:022823210262							
Address	In Date	ID#	Status	Туре	Description		
934 SELBY AVE - Golden Thyme Coffee Cafe' at Selby-Milton Apartments Mixed Use B							
	02/25/2025	<u>25 013627</u>	Active/Issuec	BS - Billboard / Sign - Signs - Commercial New	Contractor Daniel Kaufman Kaufman Sign Company - COPY TO READ: GOLDEN THYME RESTAURANT & BAR		
	02/14/2025	25 011918	Pending	XE - ECLIPS License - Entertainment - Entertainment (A)	Licensee Golden Thyme Restaurant & Bar - ECLIPS License# 20250000218		
	02/14/2025	25 011922	Pending	XL - ECLIPS License - Liquor - Liquor-Outdoor Service Area (Patio)	Licensee Golden Thyme Restaurant & Bar - ECLIPS License# 20250000218		
	02/14/2025	25 011920	Pending	XL - ECLIPS License - Liquor - Liquor On Sale - Sunday	Licensee Golden Thyme Restaurant & Bar - ECLIPS License# 20250000218		
	02/14/2025	25 011923	Pending	XL - ECLIPS License - Liquor - Liquor On Sale - 100 seats or less	Licensee Golden Thyme Restaurant & Bar - ECLIPS License# 20250000218		
	01/20/2025	25 006239	Finaled	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Rick Binder Binder Heating & A/C Inc - Per Charles, kitchen exhaust needs to e re-tested for capture/contain and interlock		
- An	01/13/2025	<u>25 004735</u>	Finaled	Water Piping - Plumbing/Inside	Contractor Mr ISAIAH COKER Ike's Plumbing & Drain Cleaning Inc - Running (1) gas line for (1) Stove		
	12/04/2024	24 098647	Closed	RF - Referral - Form 4	Owner Rondo Development On Selby Llc - Form 4 Keybox issue		
	12/04/2024	24 098646	In Compliance	CS - CSO Complaint - Certificate of Occupancy - Complaint	Form 4 Keybox issue see documents & comments		
	11/25/2024	24 096979	Finaled	EG - Fire Engineering - Special Extinguishing System - Existing Building - Alter Systems	Contractor Nardini Fire Equipment - Modification to kitchen fire suppression system		
	11/14/2024	24 094253	Finaled	M - Mechanical Permit - Refrigeration - Commercial New	Contractor Keeenan FORDER Quality Refrigeration - Install customer supplied refrigeration for (1) walk in cooler.		
	11/06/2024	24 092246	Finaled	Water Piping - Plumbing/Inside	Contractor Mr ISAIAH COKER Ike's Plumbing & Drain Cleaning Inc - EXISTING RESTAURANT ROUGHING IN (2) F/D'S, (1) ICE MAKER, (1) DISHWASHER, (1) ESPRESSO MACHINE, (1) WALL MOUNTED SINK, (1) SCRAP SINK, INSTALLING (2) GAS STOVES		
	11/04/2024	24 091695	Finaled	E - Electrical Permit - Electrical - Commercial Repair/Alter	Contractor Paul Nutting Collective Electric LLC - Cafe remodel		
	10/24/2024	24 088911	Finaled	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Escape Fire Protection - Relocate 4 heads for cooler and bar/entry area		
	10/21/2024	24 087645	Finaled	W - Warm Air, Ventilation & General Sheet - Ventilation Only - Commercial Repair/Alter	Contractor Rick Binder Binder Heating & A/C Inc - RELOCATE CEILING SUPPLY IN EXISTING OFFICE, THAT WILL BECOME NEW WALK-IN COOLER. WE WILL INSTALL NEW CEILING RETURN GRILLS IN FROM		

09/13/2024	24 077409	Finaled	E - Electrical Permit - Electrical - Residential Repair/Alter	Contractor Ccm Electric And Power Services LLC - Temp power
09/10/2024	24 076008	Finaled	B - Building Permit - Commercial - Remodel	Contractor Christian Beltran Homes By Beltran LLc - REMODEL EXISTING SPACE
09/09/2024	24 075468	Closed	RF - Referral - Form 4	Owner Rondo Development On Selby Llc - Form 4: No key for alarm panel. Need key placed in Knox box.
09/09/2024	24 075467	In Compliance	CS - CSO Complaint - Certificate of Occupancy - Complaint	Form 4: No key for alarm panel. Need key placed in Knox box.
06/26/2024	24 053600	Finaled	B - Building Permit - Commercial - Repair	Contractor Bernard Furlow Zuri 3 Construction - N/A. INTERIOR DEMO (1) INTERIOR WALL & ACT CEILING TO PREPARE FOR FUTURE TENANT REMODEL UNDER SEPARATE PERMITS
05/16/2024	24 037773	In Process	RF - Referral - C of O	Owner Rondo Development On Selby Llc - Follow up on C of O folder approved with corrections.
05/16/2024	24 037772	Pending	CO - Certificate of Occupancy - Mixed (Res+Comm)	Responsible Party Trellis Management - Building Permit 17-217869 Approval For Occupancy
12/11/2023	23 106442	Closed	RF - Referral - Citizen Complaint	Owner Rondo Development On Selby Llc - Reports of a person being trapped between two businesses in the common space were the bathrooms are located
12/11/2023	23 106441	In Compliance	CS - CSO Complaint - Certificate of Occupancy - Complaint	Reports of a person being trapped between two businesses in the common space were the bathrooms are located
10/02/2023	23 086832	Expired	BS - Billboard / Sign - Signs - Commercial New	Contractor Joelene Calvert Fastsigns Of Maple Grove-Osseo - COPY TO READ: GOLDEN THYME/ SAMMY'S
09/12/2023	23 080649	Finaled	E - Electrical Permit - Electrical - Commercial New	Contractor Ccm Electric And Power Services LLC - Temp power
06/29/2023	23 057876	Closed	RF - Referral - Citizen Complaint	Owner Rondo Development On Selby Llc - leak under sink and mold issue
06/29/2023	23 057875	In Compliance	CS - CSO Complaint - Certificate of Occupancy - Complaint	leak under sink and mold issue
09/09/2022	22 093400	Finaled	E - Electrical Permit - Electrical - Commercial New	Contractor Ccm Electric And Power Services LLC - Temp power for special event
03/25/2022	22 039534	Open	GT - General Activity Tracking - License	03/24/2022 Generate 300' ownership and email (03/25/2022) to applicant representative. JWF
02/20/2020	20 014153	Certified	CO - Certificate of Occupancy - Mixed (Res+Comm)	Responsible Party Trellis Management - Building Permit 17-217869 Approval For Occupancy
11/15/2019	19 101390	Not a CO Bldg	CO - Certificate of Occupancy - Business	Responsible Party Chdc Rondo Limited Partnership - 05/20/20 Not a CO Building.
11/06/2019	19 099312	Finaled	E - Electrical Permit - Electrical - Commercial New	Contractor Wjrj Electrical LLC - ADDING 2 FIRE ALARM STROBES
11/06/2019	19 099310	Finaled	EG - Fire Engineering - Alarm Permit - Existing Building - New Systems	Contractor Wjrj Electrical LLC - ADDING FIRE ALARM (2) STROBES
11/06/2019	19 099309	Withdrawn	E - Electrical Permit - Electrical - Commercial New	Contractor Wjrj Electrical LLC - ADDING FIRE ALARM (2) STROBES 11.6.19 CLERICAL ERROR, SLH
10/18/2019	19 093968	Finaled	EG - Fire Engineering - Sprinkler / Standpipe Permit - Existing Building - Alter Systems	Contractor Jan Kinney Ahern Fire Protection - Extend approximately 18 sprinklers for new ceiling grid in coffee shop
06/05/2019	19 047652	Finaled	PG - Plumbing/Gasfitting/Inside	Contractor Mr ISAIAH COKER Ike's Plumbing & Drain Cleaning Inc - (1) PREP SINK, (2) HAND SINKS, (1) 3- COMPARTMENT SINK, (1) MOP SINK AND (4) GAS RANGES
06/04/2019	19 047160	Finaled	E - Electrical Permit - Service & Circuits - Commercial	Contractor L & J Electrical LLC - REMODEL KITCHEN AND DINNING

		Repair/Alter	AREA
04/12/2019 <u>19 030</u>	456 Finaled	B - Building Permit - Commercial - Repair	Contractor Chdc Rondo Limited Partnership - N/A. SAC PAYMENT ONLY
04/11/2019 <u>19 030</u>	<u>281</u> Finaled	B - Building Permit - Commercial - Remodel	Contractor Chdc Rondo Limited Partnership - FRAMING & SHEET ROCKING OF NON-STRUCTURAL INTERIOR WALLS
11/07/2018 <u>18 121</u>	120 Finaled	EG - Fire Engineering - Special Extinguishing System - Existing Building - Alter Systems	Contractor Diane Wendt Summit g Companies - INSTALL 4.5 GALLON ANSUL SYSTEM
10/23/2018 <u>18 116</u>	189 Inspected	M - Mechanical Permit - Gas - Commercial New	Contractor David Rouse S R Mechanical - 2 FURNACE - A/C SPIT (2-4 TON) 1 MAKE UP AIR FOR KITCHEN - 94% EFF
07/11/2018 <u>18 082</u>	485 Withdrawn	B - Building Permit - Mixed (Commercial/Residential) - Remodel	Contractor Watson Forsberg CO - BUILD-OUT OF NEW TENANT SPACE IN 940 SELBY AVE, WORK INCLUDES NEW COMMERCIAL KITCHEN, POINT OF SALE, MEETING ROOM, & SEATING SPACE WITH NEW WALL & CEILING FINISHES THROUGHOUT WITHDRAWN - NEW CONTRACTOR
06/18/2018 <u>18 074</u>	116 Expired		Recontractor Joseph Daugherty P & D Mechanical Contracting CO - NEW RESTAURANT IN NEW BLDG - ELECTRIC WATER HEATER & GAS DEVICES - GAS FRYER, OVEN, CHAR BROILER - 6/26/18 revised plans rec. U.R R.J 6/26/18 plans must be signed. 6/25/18 The plans submitted must be revised showing the installation of a code complaint grease interceptor isometric drawings of the waste, vent, waters and rainwater leaders if applicable. Provide 2 hard copies with revisions. R.J. called cont. message with Bill D. 6/18/18 U/R plans rec. R.J.