



CITY OF SAINT PAUL

375 Jackson Street, Suite 220  
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989  
Facsimile: 651-266-8951  
Web: [www.stpaul.gov/dsi](http://www.stpaul.gov/dsi)

August 16, 2021

PANG F MOUA  
8606 TIMBERWOOD ROAD  
WOODBURY MN 55125-7621

## FIRE INSPECTION CORRECTION NOTICE

RE: 67 MAGNOLIA AVE W  
Ref. #106391  
Residential Class: B

Dear Property Representative:

Your building was inspected on August 16, 2021 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made **on September 16, 2021 at 11:00AM.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

**YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.**

### DEFICIENCY LIST

1. Unit 1 - Bathroom - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code. **-Provide missing light bulbs.**

2. Unit 2 - Rear entry - MSFC 1008.1.9.3 - Remove unapproved locks from the exit doors. The door must be openable from the inside without the use of keys or special knowledge or effort. **-Remove slide lock.**

3. Unit 2 - Rear stairs - SPLC 34.09 (3), 34.33(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. This work may require a permit(s). Call DSI at (651) 266-8989. **-Repair or replace loose and deteriorated stairs.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: [Torrance.Harriel@ci.stpaul.mn.us](mailto:Torrance.Harriel@ci.stpaul.mn.us) or call me at 651-266-8941 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Torrance Harriel  
Fire Safety Inspector

Reference Number 106391