



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
St Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

October 06, 2022

NOTICE OF CONDEMNATION AS UNFIT FOR HUMAN HABITATION & ORDER TO VACATE

Jennifer Williams
621 Bidwell St
St Paul MN 55107-5200

Dear Sir or Madam:

The Department of Safety and Inspections, Division of Code Enforcement, has determined that the dwelling and premises at **621 BIDWELL ST** is "Unfit for Human Habitation". In accordance with Saint Paul Legislative Code, Chapter 34, Section 23, the premises will be placarded on **October 5, 2022**, and ordered vacated no later than **October 5, 2022**.

Your attention is called to the following provisions of Section 34.23, Subsection 6 entitled, *Vacation of Structure or Unit*:

“Any dwelling unit, structure or portion thereof which has been condemned or placarded as unfit for occupancy shall be vacated within the time set forth in the placard and/or order. No person shall occupy or let for occupancy any structure which is condemned.”

THIS DWELLING SHALL NOT AGAIN BE USED FOR HUMAN HABITATION UNTIL WRITTEN APPROVAL IS SECURED FROM THE CITY OF SAINT PAUL; DEPARTMENT OF SAFETY AND INSPECTIONS, DIVISION OF CODE ENFORCEMENT.

Principle Violations: These deficiencies must be corrected before this condemnation and vacate order will be removed.

1. SPLC 34.23 **CONDEMNATION:** This occupancy is condemned as unsafe or dangerous. It constitutes a condition of material endangerment to occupants and emergency personnel. The interior of home has gross unsanitary conditions **due to fire and smoke damage on 10-4-2022. Hole in the living room roof due to the fire damage.**
2. SPLC 34.11 **GAS:** Lack of Natural Gas Service. Immediately restore natural gas service. Failure to provide natural gas service will result in these premises being declared Unfit for Human Habitation and ordered vacated for lack of this basic facility. **GAS METER LOCKED DUE TO FIRE TO THE PROPERTY.**
3. SPLC 34.11 **ELECTRIC:** Lack of Electricity. Immediately restore electrical service. Failure to provide proper electrical service will result in these premises being declared Unfit for Human Habitation and ordered vacated for lack of this basic facility. Use of candles, fuel operated lighting or extension cord wiring is not permitted while the power is off. **ELECTRIC LOCKED DUE TO FIRE TO THE PROPERTY.**

Authorization to reoccupy this/these dwelling unit(s) will not be given until it is demonstrated that all principal violations have been corrected and that no new conditions exist which could constitute material endangerment, or which threaten the peace, health, safety or welfare of the occupants of this building.

All repairs and new installations must be made in accordance with the appropriate codes. Permit information may be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989.

You may file an appeal to this notice by contacting the City Clerk's Office at (651) 266-8585. Any appeal must be made in writing within 10 days of the date of this notice.

It is the responsibility of the property owner to keep all buildings secured and to properly maintain the premises at all times.

If you have any questions concerning this matter, please contact the Inspector, Sean Westenhofer, at 651-266-1914. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to the inspector.

Sincerely,

Sean Westenhofer
Code Enforcement Officer

sw

cc: Posted to ENS