

2018 IFC Amended

CONTENTS

Effective Date: Mar 31, 2020 Version: Mar 2020 ▼

2020 Minnesota State Fire Code

Dispensing Facilities.

2304.3 Unattended Self-Service Motor Fuel-

○ NOTES

Dispensing Facilities. 2304.3.1 General.

2304.3.2 Dispensers.

2304.3.3 Emergency Controls.

2304.3.4 Operating Instructions.

2304.3.5 Emergency Procedures.

2304.3.6 Communications.

2304.3.7 Quantity Limits.

- > 2304.4 Dispensing Into Portable Containers.
- > Section 2305 Operational Requirements
- Section 2306 Flammable and Combustible Liquid Motor Fuel-Dispensing Facilities
- Section 2307 Liquefied Petroleum Gas Motor Fuel-Dispensing Facilities
- Section 2308 Compressed Natural Gas Motor > Fuel-Dispensing Facilities

Codes / Minnesota / 2020 Minnesota State Fire Code V

2304.3.6 Communications.

Search Digital Codes

A telephone not requiring a coin to operate or other approved, clearly identified means to notify the fire department shall be provided on the site in a location approved by the fire code official.

Q

2304.3.7 Quantity limits.





▦

Dispensing equipment used at unsupervised locations shall comply with one of the following:

- 1. Dispensing devices shall be programmed or set to limit uninterrupted fuel delivery to 25 gallons (95 L) and require a manual action to resume delivery.
- 2. The amount of fuel being dispensed shall be limited in quantity by a preprogrammed card as approved.

2304.4 Dispensing into portable containers.

The dispensing of flammable or combustible liquids into portable approved containers shall comply with Sections 2304.4.1 through 2304.4.3.

2304.4.1 Approved containers required.

Class I, II and IIIA liquids shall not be dispensed into a portable container unless such container does not exceed a 6-gallon (22.7 L) capacity, is listed or of approved material and construction, and has a tight closure with a screwed or spring-loaded cover so designed that the contents can be dispensed without spilling. Liquids shall not be dispensed into portable or cargo tanks.

2304.4.2 Nozzle operation.

A hose nozzle valve used for dispensing Class I liquids into a portable container shall be in compliance with Section 2306.7.6 and be manually held open during the dispensing operation.