



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

July 16, 2021

Jordan Elizabeth Seitz
6203 Eagle Lake Dr
Maple Grove MN 55369-6207

**NOTICE OF CONDEMNATION
UNFIT FOR HUMAN HABITATION
ORDER TO VACATE**

RE: 838 3RD ST E
Ref. # 14089

Dear Property Representative:

Your building was inspected on July 16, 2021.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. Basement - SPLC 34.10 (3), 34.34(2) - Provide an approved handrail. The top of the handrail must be between 34 and 38 inches above the treads and run the entire length of the stair.-

2. Basement - SPLC 34.10 (3) 34.34(2) - Provide an approved guardrail. Intermediate balustrade must not be more than 6 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.-
3. Building - SPLC 34.09 (4), 34.33 (3) - Repair and maintain the window glass.-
4. Building - SPLC 34.09 (4), 34.33 (3) -Provide or repair and maintain the window screen.-
5. Front porch and - throughout - SPLC 34.16 (2) - Properly dispose all of your garbage in the owner-provided containers.-
6. Interior stairways - MSFC 1030.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exit path..-
7. Rear Porch - MSFC 304.1 - Remove excessive combustible storage and/or vegetation from exterior property areas.-
8. Rear yard - MSFC 304.1 - Remove excessive combustible storage and/or vegetation from exterior property areas.-
9. Rear of Building - SPLC 163.03, 163.01 (2), (3) - Currently license (tabs) all vehicles on the property and return the vehicles to an operative mechanical condition or remove vehicles from the property.-
10. Rear of building - & front porch - SPLC 34.08 (6) - Remove the accumulation of exterior storage that creates a nuisance or harbors rodents.-
11. MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.-
12. MSFC 307.1 - All fires on the ground must be a minimum of 25 feet from structures or contained in a grill or outdoor fireplace. Wind speeds must be under 10 mph, constantly attended, a means of extinguishment must be provided. Only natural firewood can be burned (no construction materials, brush or waste materials), and fire shall be extinguished if the smoke is deemed a nuisance. A citation will be issued for non-compliance.-

13. SPLC 34.09 (1)(2), 34.33 (1) - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-
14. MSFC 308.1.2 - No person shall throw or place, or cause to be thrown or placed, a lighted match, cigar, cigarette, matches, or other flaming or glowing substance or object on any surface or article where it can cause an unwanted fire.-
15. SPLC 34.08 (1), 34.34 (4), 34.16 - Provide and maintain interior in a clean and sanitary condition.-
16. MSFC 315.3.3 - Remove combustible storage within 36 inches of fuel burning equipment.-
17. MSFC 603.5.3 - Provide clearance around all mechanical equipment.-
18. MN Stat. 299F.362 - Immediately provide and maintain a smoke detector located outside each sleeping area.-
19. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.-
20. SPLC 39.02(c) - Complete and sign the smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector
Ref. # 14089