



April 11, 2023  
Ben Kieffer  
Ben Kieffer  
3370 ANNAPOLIS LANE N SUITE C  
PLYMOUTH MN 55447 USA

### **CORRECTION NOTICE - COMPLAINT INSPECTION**

RE: 198 6TH ST E  
Ref. # 59693

Dear Property Representative:

A referral has been made to our office regarding code deficiencies that are reported to exist in your building or on the premises. An inspection has not been conducted by the Fire Prevention Division. If these deficiencies do in fact exist, you are hereby notified that the following deficiencies must be corrected immediately.

**An inspection will be made on or after May 19, 2023.**

#### **DEFICIENCY LIST**

1. Stairwell - MSFC 506.1 - Where required. Where access to or within a structure or an area is unduly difficult because of secured openings or where immediate access is necessary for life-saving or firefighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official. Exception: One- and two-family dwellings need not be provided with lock boxes. **Provide the correct keys to the stairwell doors. Call the fire department communication center at 651-266-7702 to have the key box opened.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: [travis.almsted@ci.stpaul.mn.us](mailto:travis.almsted@ci.stpaul.mn.us) or call me at 651-266-8977 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Travis Almsted  
Fire Safety Inspector II

Ref. # 59693