



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

August 4, 2022

CLEMENT MARRIOT
1430 CONCORDIA AVE PO BOX 40295
ST PAUL MN 55104 USA

FIRE INSPECTION CORRECTION NOTICE

RE: 703 CASE AVE
Ref. #107758
Residential Class: A

Dear Property Representative:

Your building was inspected on August 4, 2022, for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on August 8, 2022, at 2:00 pm.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - MSBC -Section 105.1 - Permits Required. Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, the installation of which is regulated by this code, or to cause any such work to be done, shall first make application to the building official and obtain the required permit. Work being done requires a permit. -Water heater replaced without permit.

2. Unit 2 - Upper Level - MN Stat. 299F.362, MSFC 1103.8 - Immediately provide and maintain a smoke alarm located outside each sleeping area. Replace missing smoke alarms from brackets, in sleeping room and kitchen.
3. Unit 2 - Upper Level - SPLC 34.10 (7), 34.17 (5) - Repair and maintain the walls in an approved manner. Holes in wall, adjacent to bedroom doorway.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: der.vue@ci.stpaul.mn.us or call me at 651-266-8988 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Der Vue
Fire Safety Inspector
Reference Number 107758