



November 14, 2024

Yong Gang Dong
1649 EDMUND AVE
ST PAUL MN 55104USA

**NOTICE OF CONDEMNATION
UNFIT FOR HUMAN HABITATION
ORDER TO VACATE**

RE: 1484 CHARLES AVE
Ref. # 118461

Dear Property Representative:

Your building was inspected on November 14, 2024.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed, or the building vacated by the re-inspection date.

A reinspection will be made on or after February 14, 2025.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. Entire Property - SPLC 34.23, MSFC 111.1 - This occupancy is condemned as unfit for human habitation. This occupancy must not be used until re-inspected and approved by this office. -Due to, but not limited, to gross and unsanitary conditions, excessive content throughout property, water damage, illegal locks on sleeping rooms, inoperable and lack of smoke and carbon monoxide alarms and overoccupancy.
2. SPLC 39.02(c) - Complete and sign the smoke alarm affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: der.vue@ci.stpaul.mn.us or call me at 651-266-8988 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

Der Vue
Fire Safety Supervisor
Ref. # 118461

cc: Housing Resource Center
Force Unit