



April 3, 2023

JIM BERN COMPANY
8162 BLOOMINGTON AVE S
BLOOMINGTON MN 55425

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
2234 GLENRIDGE AVE

Ref. # 107397

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on April 3, 2023. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. A reinspection will be made on April 11, 2023 at 9:15AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. 2236 - MMC 504.1 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work SHALL require a permit(s). Call DSI at (651) 266-8989.-
2. 2236 - SPLC 34.23, MSFC 111.1 - This occupancy is condemned as unsafe or dangerous. This occupancy must not be used until re-inspected and approved by this office.-
3. Basement and through the house - 2236 - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials.-Reduce basement 80% Reduce through out house 50%

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector
Ref. # 107397