



# Fire Inspection Report

**City of Saint Paul**  
 Department of Safety and Inspections  
 375 Jackson Street – Suite 220  
 Saint Paul MN 55101-1806

Owner Name ATNAFU YESHIDAGNE  
 Owner Address ATNAFU2001@gmail.com  
 City State Zip \_\_\_\_\_  
 Owner Phone 612.408.4096

License CONTRACTOR DJ  
 Complaint 612.790-2941  
 C of O \_\_\_\_\_  
 Date 3/9/2023

**Building Address:** 510 SNELLING AVE NORTH

You are hereby notified to remedy the conditions stated below immediately. A reinspection will be made after the reinspection date stated below. If you consider any of these code requirements to be unreasonable, you may appeal to the Legislative Hearing Officer. Applications for appeals may be obtained at the City Clerks Office, 310 City Hall 651-266-8585 within 10 days of the date of the original orders.

Code	Conditions to be Corrected
MSBC	OBTAIN INSPECTIONS FOR CONSTRUCTION IN 506 SNELLING AVE - MAY NEED TO OPEN WALLS AND CEILING (ADD BOLLARDS; AC PAD)
MMC	OBTAIN INVOICE AND PROTECT PROPOSAL FOR VENTILATION CORRECTIONS AN EXHAUST DUCT WORK AND FAN ASSEMBLY, CONTRACTOR TO SUBMIT PLANS TO WARM-AIR INSPECTIONS FOR REVIEW AND PERMIT ISSUING, PROVIDE COPY OF PROPOSAL TO LHO.
MSPC	GAS PLUMBING INSPECTION REQUIRED FOR INSTALLATION OF GAS RANGE.
MSPC	ANSUL SYSTEM IS OVERDUE, CONTACT CONTRACTOR AND HAVE THIS SERVICED - IMMEDIATELY.

Owner or Representative Signature \_\_\_\_\_ *[Signature]*

Occupancy Type BUSINESS Inspector Signature Jaura Huseby

CFO Key \_\_\_\_\_ Reinspection Date TBD

\* \* For further information on this report, contact the Fire Inspection Division at 651-266-8989 \* \*