



September 16, 2024

UPDOWN PROPERTY MANAGEMENT  
1400 VAN BUREN ST NE SUITE 200-240  
MINNEAPOLIS MN 55413 USA

### **CORRECTION NOTICE - COMPLAINT INSPECTION**

RE: 1083 CHATSWORTH ST N  
Ref. # 15402

Dear Property Representative:

An inspection was made of your building on September 16, 2024, in response to a referral. You are hereby notified that the following deficiency list must be corrected immediately. A reinspection will be made **on or after November 15, 2024**.

Failure to comply may result in a criminal citation or revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

#### **DEFICIENCY LIST**

1. Exterior - Garage - SPLC 34.08 (5), 34.32 (3) - All accessory structures including, but not limited to, detached garages, sheds and fences shall be maintained structurally sound and in good repair. Provide and maintain exterior unprotected surfaces painted or protected from the elements. **-Repair and maintain the garage. (Extensive fire damage.)**
2. Interior - All units - SPLC 34.23, MSFC 111.1 - This occupancy is condemned as unsafe or dangerous. This occupancy must not be used until re-inspected and approved by this office. **-Building has sustained major fire damage. Units are condemned.**

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>.

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: [Torrance.Harriel@ci.stpaul.mn.us](mailto:Torrance.Harriel@ci.stpaul.mn.us) or call me at 651-266-8941 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Torrance Harriel  
Fire Safety Inspector  
Ref. # 15402