



April 14, 2023

Community Stabilization Project
501 DALE ST N
ST PAUL MN 55103

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1129 BEECH ST
Ref. # 124226

Dear Property Representative:

Your building was inspected on April 14, 2023, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on May 15, 2023 at 12Noon or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. Basement stairway - SPLC - sec 34.33 Stairs steps deemed hazardous by the enforcement officer shall be corrected in accordance with the building code in which it was constructed . Repair the steps-
2. SPLC 39.02(c) - Complete and sign the smoke alarm affidavit and return it to this office.
3. SPLC 34.11 (1), MSBC 2902.1, SPLC 34.35 (1), MPC 301.1 - Repair or replace and maintain all parts of the toilet seat cover.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector

Ref. # 124226