

## Mai Vang

---

**From:** kelly vang <kvang3570@yahoo.com>  
**Sent:** Thursday, February 20, 2025 12:17 PM  
**To:** Mai Vang  
**Subject:** Fw: 705 Magnolia Ave

You don't often get email from kvang3570@yahoo.com. [Learn why this is important](#)

**Think Before You Click: This email originated outside our organization.**

8th email corresponding. This is with Clint from building inspection.

[Sent from Yahoo Mail for iPhone](#)

Begin forwarded message:

On Tuesday, June 25, 2024, 8:11 AM, Clint Zane <Clint.Zane@ci.stpaul.mn.us> wrote:

Hello Kelly,

I am reaching out because the legislative team is wondering why this one is not complete. The mechanical inspector Aaron Havlicek and I left you a message some time back letting you know that you still needed to support the fresh air duct and provide a proper screen in the exterior dryer vent. The inside is sealed properly and insulated as I required, but the exterior vent with damper and bird screen is not compliant. Last time I looked at it there was just some screen stuffed up inside the existing vent cover. You will need a new vent cover with damper and ¼"x1/4" bird screen. If you have questions about the type and minimum spacing between supports for the fresh air duct, you may ask Aaron whom I've CC'd here. When this is done and inspected, Aaron will sign off on the mechanical and I can then issue the certificate of code compliance. Until then occupancy is still not allowed.

Regards,



The Most Livable  
City in America

**Clint Zane**

**Code Compliance Officer**

**Building Inspector**

Department of Safety and Inspections  
375 Jackson Street, Suite 300  
Saint Paul, MN 55101

**P:** 651-266-9029

**C:** 651-248-3860

[Clint.Zane@ci.stpaul.mn.us](mailto:Clint.Zane@ci.stpaul.mn.us)



Making Saint Paul the Most Livable City in America

***DSI's Mission: "To preserve and improve the quality of life in Saint Paul by protecting and promoting public health and safety for all."***